## **Certificate of Assessment**

Job No.: NK7362 No. 2217

"Copyright CSIRO 2015 ©"
Copying or alteration of this report without written authorisation from CSIRO is forbidden.

This is to certify that the specimen described below was tested by the CSIRO Infrastructure Technologies in accordance with Australian/ New Zealand Standard 3837, Method of test for heat and smoke release rates for materials and products using an oxygen consumption calorimeter, 1998, at 50 kW/m², on behalf of:

New Age Veneers Pty Ltd Unit 14, 22-44 Beaumont Road MOUNT KURING-GAI NSW 2080 AUSTRALIA

A full description of the test specimen and the complete test results are detailed in the Division's sponsored investigation report numbered FNK 11440.

**SAMPLE** 

**IDENTIFICATION:** Navform

**DESCRIPTION OF** 

**SAMPLE:** The sponsor described the tested specimen as a decorative film-faced

medium density fibreboard (MDF) panel. The decorative film was adhered on the exposed face of the MDF using cross-linking polyethylene-vinyl acetate

(EVA) adhesive at an application rate of 15 m<sup>2</sup>/L.

Nominal thickness of decorative film: 0.015-mm
Nominal thickness of MDF: 4-mm
Nominal total mass: 3.5 kg/m²
Nominal total density: 290 kg/m³
Colour: dark brown

**SAMPLE** 

**CLASSIFICATION:** Group Number: Group 3

(In accordance with Specification A2.4 of the Building Code of Australia.)

Average specific extinction area: 56.5 m<sup>2</sup>/kg

(Refer to Specification C1.10 section 4(c) of the Building Code of Australia.)

Testing Officer: Heherson Alarde Date of Test: 13 July 2015

Issued on the 23<sup>rd</sup> day of July 2015 without alterations or additions.

**Brett Roddy** 

Team Leader, Fire Testing and Assessments



NATA Accredited Laboratory
Number: 165
Corporate Site No 3625
Accredited for compliance with ISO/IEC 17025.

**CSIRO** INFRASTRUCTURE TECHNOLOGIES

