

Emission Test Certificate

Monday 22nd July 2024

Manufacturer	New Age Veneers Pty Ltd (Unit 14, 22-24 Beaumont Road, MT KURING-GAI, NSW, 2080, Australia).
Brand Name	Shinnoki Panel.
Date Tested	June 2024 (Tested by FORAY Laboratories – NATA Accreditation 1231)
Test Method	ASTM D5116-2017 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data (24 hrs):

Green Building Council of Australia Green Star Design & As Built V1.3 - 13.1.2B & 13.2 Green Star Interiors V1.3 - 12.2	Shinnoki Panel
Total Volatile Organic Compound (C ₆ -C ₁₆) Emission Rate Limit: ≤0.500 mg/m ² /hr	Total Volatile Organic Compound (C ₆ -C ₁₆) Emission Rate: 0.049 mg/m ² /hr
Formaldehyde Emission Rate Limit: ≤ 0.100 mg/m ² /hr	Formaldehyde Emission rate: 0.072 mg/m ² /hr

Dr. Vyt Garnys
PhD, BSc (Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

Travis Hale
BSc (Biotechnology)
Senior Consultant

Dr. Tuan Duong
PhD, B.Eng. (Chemical)
Senior Consultant

Issued date: 22/7/2024

Expiry date: 22/7/2029

P24060099